



ORIGINAL PERMIT APPLICANT(S)

BLUE VALLEY METROPOLITAN DISTRICT

APPROVED WELL LOCATION

Water Division: 5 Water District: 36
 Designated Basin: N/A
 Management District: N/A
 County: GRAND
 Parcel Name: N/A

AUTHORIZED AGENT

BALCOMB & GREEN (PETERSON, BLAKE)
 BALCOMB & GREEN (STOEBER, LISA)
 BALCOMB & GREEN PC (GROSSCUP, SCOTT)

Lot: P Block: Filing:
 Physical Address: N/A
 NW 1/4 SW 1/4 Section 34 Township 1.0 S Range 80.0 W Sixth P.M.

UTM COORDINATES (Meters, Zone:13, NAD83)

Easting: 385254.5 Northing: 4419783.7

PERMIT TO USE AN EXISTING WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT
CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not assure the applicant that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-90-137(2) to use an existing well in conjunction with permit no. 49622-F, on the condition that this well is operated in accordance with the Blue Valley Metropolitan District Augmentation Plan approved by the Division 5 Water Court in case no. 22CW3086. If this well is not operated in accordance with the terms of said decrees, it will be subject to administration including orders to cease diverting water. This well is known as Blue Valley Metropolitan District Pump and Pipeline, 1st Enlargement.
- 4) The use of groundwater from this well, in addition to those uses allowed per permit no. 49622-F, is limited to domestic for use inside up to 27 residences.
- 5) The maximum pumping rate of this well shall not exceed 250 GPM and the cumulative diversion rate under any combination of the Blue Valley Metropolitan District 1998 Well Nos. 1 & 2, the Blue Valley Metropolitan District 1998 Well Nos. 1 & 2, 1st Enlargement, the Blue Valley Metropolitan District Pump & Pipeline, and the Blue Valley Metropolitan District Pump & Pipeline, 1st Enlargement, shall not exceed 250.0 GPM at one time, as decreed.
- 6) The annual withdrawal of ground water from this well, in addition to the withdrawal allowed permit no. 49622-F, shall not exceed 9.527 acre-feet. The cumulative annual diversion amount under any combination of the Blue Valley Metropolitan District 1998 Well Nos. 1 & 2, 1st Enlargement and the Blue Valley Metropolitan District Pump & Pipeline, 1st Enlargement, shall not exceed 9.527 acre-feet, as decreed.
- 7) The return flow from the use of this well must be through individual wastewater disposal systems of the non-evaporative type where the water is returned to the same stream system in which the well is located.
- 8) The owner shall mark the well in a conspicuous place with well permit number(s), name of the aquifer, and court case number (s) as appropriate. The owner shall take necessary means and precautions to preserve these markings.
- 9) A totalizing flow meter must be installed on this well and maintained in good working order. Permanent records of all diversions must be maintained by the well owner (recorded at least annually) and submitted to the Division Engineer upon request.
- 10) This well shall be located not more than 200 feet from the location specified on this permit and as decreed in Division 5 Water Court case no. 22CW3086.
- 11) This well shall be located more than 600 feet from any existing well, completed in the same aquifer, that is not owned by the applicant.
- 12) The well shall be constructed and maintained in accordance with variance no. 98-33A, granted by the Board of Examiners of Water Well Construction and Pump Installation Contractors on February 10, 1998.

WELL PERMIT NUMBER 89057-F

RECEIPT NUMBER 10033987



Date Issued: 4/16/2024

Expiration Date: N/A

Issued By JUSTINA MICKELSON